



Supplementary File 1 – HFM Proteus SmartMode 8.5 Measurement Screenshots

2.1.1



2.1.2



2.1.3

NETZSCH
SmartMode 8.5

Favorites

User Methods

Wizards

AutoCalibration

Measurement

Reports

Setup & Control

HFM 446 S

IDLE
22.5 °C

Thermal Conductivity Calibration

Basic Data

LaboratoryMNEXT

ProjectJoVE

Operator NameFran

RemarkOptional

Identity or NameFran

Reference Description

Setpoints

Heating Rate2.00 K/min

	Use	Mean Temp. [°C]	ΔT [K]	Upper Plate [°C]	Lower Plate [°C]	Thermal Conductivity [W/(m·K)]		
1	☒	10.0	15.0	17.5	2.5	0.0313	+	×
2	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
3	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
4	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
5	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
6	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
7	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
8	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
9	☐	0.0	20.0	10.0	-10.0	0.0302	+	×
10	☐	0.0	20.0	10.0	-10.0	0.0302	+	×

Reload

Start

Rerun

2.1.4

NETZSCH
SmartMode 8.5

Favorites

User Methods

Wizards

AutoCalibration

Measurement

Reports

Setup & Control

HFM 446 S

IDLE
21.3 °C

HFT Calibration Reference Material

Reference Description

Reference IDNetzch

NameEPS

MaterialEPS

TypeNETZSCH EPS

Select

Temperature Range

Minimum2.5 °C

Maximum17.5 °C

Mass

175.00 g

Density

87.50 kg/m³

Thickness

5.0000 cm

Shape: Rectangle

Width20.0 cm

Depth20.0 cm

Shape: Round

Diameter0.0 cm

Save

Copy

2.1.5

NETZSCH SmartMode 8.5

HFM 446 S
IDLE
22.2 °C

Thermal Conductivity Calibration

	0.0	20.0	10.0	-10.0	0.0302			
5	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒
6	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒
7	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒
8	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒
9	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒
10	☐	0.0	20.0	10.0	-10.0	0.0302	☒	☒

Run Parameters

Door state: Closed Open Close Stop

☒ Load setpoint

☒ Pressure 2.1 kPa
Current load pressure: 0.0 kPa

☐ Force 84.0 N Apply Stop
Current load force: 1.1 N

☐ Thickness 0.0000 cm
Current thickness: 5.0483 cm
Max. Force: 0.0 N

Thermocouple: Average Change
Heat Flux sensors: Both
Instrumentation Kit: Not Used

Stability: HFT Calibration Select Manage
☐ Max. Setpoint/Step Duration: 0 min

Reload Start Rerun

2.1.6

NETZSCH SmartMode 8.5

HFM 446 S
ECO
24.5 °C

Thermal Conductivity Test

Specific Heat Test

Product Type Manager

2.1.7

NETZSCH SmartMode 8.5

HFM 446 S
ECO
24.5 °C

Thermal Conductivity Test

A Basic Data

Laboratory: MNEXT
Project: JoVE
Operator Name: Fran
Remark: Optional

Directory: C:\NETZSCH
File Name: Test 1 .ngb-sh4

A Specimen Description

Product Type: MBC [Select] [Manage]

Sample ID: MBC1
Sample Name: MBC1
Material: MBC
Spacers: Optional

☒ Mass: 100.00 g
☐ Density: 66.46 kg/m³

☒ Use thickness gauge: 3.7619 cm
☐ User defined thickness: 3.6400 cm

Width: 20.0 cm
Depth: 20 cm [15.0 - 20.3] cm

A Setpoints

[Reload] [Start] [Save] [Load]

2.1.9

NETZSCH SmartMode 8.5

HFM 446 S
ECO
24.5 °C

Thermal Conductivity Test

9 ☐ 0.0 20.0 10.0 -10.0 + -
10 ☐ 0.0 20.0 10.0 -10.0 + -

A Run Parameters

Heat Flux Sensor Calibration: 0142-O_Cal 1450D_25644_#1 [Select] [Manage]

Reference material: 25644 (1450 D)
Calibration date: 21/06/2024 12:08
Temperature range: -10.0 °C ... 80.0 °C

Door state: Closed [Open] [Close] [Stop]

☒ Load setpoint

☒ Pressure: 2.1 kPa [0.0 - 21.3] kPa

☐ Force: Current load pressure: 1.3 kPa
Current load force: 84.0 N [Apply] [Stop]

☐ Thickness: Current thickness: 3.7619 cm
Max. Force: 0.0 N


☐ Remove stack after test from sample to offset: 3.0000 cm

Thermocouple: Average
Heat Flux sensors: Both [Change]
Instrumentation Kit: Not Used


Stability: Standard [Select] [Manage]
☐ Max. Setpoint/Step Duration: 0 min

[Reload] [Start] [Save] [Load]

2.2.1



2.2.2



2.2.3

NETZSCH
SmartMode 8.5

Favorites

User Methods

Wizards

AutoCalibration

Measurement

Reports

Setup & Control

www.netzsch.com

HFM 446 S

ECO

24.5 °C

Empty Stack Correction

RemarkOptional

Identity or NameFran

Steps

	Start Temperature [°C]	End Temperature [°C]	Cp Setpoint [°C]	
1	0.0	20.0	10.0	+ -
2	20.0	40.0	30.0	+ -
3	40.0	60.0	50.0	+ -

First Mean Temperature10.0 °C
Last Mean Temperature30.0 °C
Number of Steps2

Generate

Temperature: -20.0 - 90.0 °C
End temperature must be greater than start temperature

Run Parameters

Heat Flux Sensor Calibration0142-O_Cal 1450D_25644_#1

SelectManage

Reference material:25644 (M59 D)
Calibration date:21/08/2024 12:08
Temperature range:-30.0 °C - 80.0 °C

Door state:Closed

OpenCloseStop

Drive Plate to Thickness0.2500 cm

ApplyStop

Current thickness:3.7619 cm

ThermocoupleAverage

Heat Flux sensorsBoth

Change

Instrumentation KitNot Used

StabilityEmpty Stack Correction

SelectManage

☐ Max. Setpoint/Step Duration0 min

ReloadStart

2.2.4

NETZSCH
SmartMode 8.5

Favorites

User Methods

Wizards

AutoCalibration

Measurement

Reports

Setup & Control

www.netzsch.com

HFM 446 S

ECO

24.5 °C

Thermal Conductivity Test

Specific Heat Test

Product Type Manager

2.2.6

NETZSCH SmartMode

NETZSCH
SmartMode 8.5

HF146 S
IDLE
20.9 °C

← Specific Heat Test

A Basic Data

Laboratory: MNEXT
Project: JoVE
Operator Name: Fran
Remark: Optional

Directory: C:\NETZSCH
File Name: MBC1 .ngb-sh4

A Specimen Description

Product Type: MBC Select Manage

Sample ID: MBC1
Sample Name: MBC1
Material: MBC
Spacers: Optional

☒ Mass: 210.00 g
☐ Density: 104.00 kg/m³

☒ Use thickness gauge: 5.0483 cm
☐ User defined thickness: 3.6400 cm

Width: 20.0 cm
Depth: 20 cm [15.0 - 20.3] cm

A Steps

Reload Start

2.2.7

NETZSCH SmartMode

NETZSCH
SmartMode 8.5

HF146 S
IDLE
20.7 °C

← Specific Heat Test

2 ☒ 20.0 40.0 30.0
3 ☒ 40.0 60.0 50.0
Temperature: -20.0 ... 90.0 °C
End temperature must be greater than start temperature

A Run Parameters

Heat Flux Sensor Calibration: 0142-O_Cal 1450D_25644_#1 Select Manage

Reference material: 25644 (M50 D)
Calibration date: 21/08/2024 12:08
Temperature range: -10.0 °C ... 80.0 °C

Door state: Closed Open Close Stop

☒ Load setpoint

☒ Pressure: 2.1 kPa
Current load pressure: 0.0 kPa

☐ Force: 84.0 N Apply Stop
Current load force: 1.1 N

☐ Thickness: 0.0000 cm
Current thickness: 5.0483 cm
Max. Force: 0.0 N

☐ Remove stack after test from sample to offset: 3.0000 cm

Thermocouple: Average
Heat Flux sensors: Both Change
Instrumentation Kit: Not Used

Stability: CP Test Select Manage
☐ Max. Setpoint/Step Duration: 0 min

Reload Start

2.2.8

NETZSCH SmartMode 8.5

HFM 446 S
IDLE
0.0 °C

New reports

- File Browser
- Lambda 90/90

Reports Configuration

- Configure

Recent measurements

MBC1.ngb-sh4 Specific Heat Test	23/04/2023 13:30:51 End of Measurement (user reset).	[Icon]
Test 1.ngb-sh4 Thermal Conductivity Test	23/04/2023 12:54:02 End of Measurement (user reset).	[Icon]
MBC_NN_B3_S6_PG_03.04_20250422_1031.ngb-sh4 Thermal Conductivity Test	22/04/2023 11:56:59 End of Measurement (normal).	[Icon]
MBC_NN_B3_S9_PG_03.04_20250417_1502.ngb-sh4 Thermal Conductivity Test	17/04/2023 16:09:51 End of Measurement (normal).	[Icon]
MBC_NN_B3_S7_PG_03.04_20250417_1340.ngb-sh4 Thermal Conductivity Test	17/04/2023 14:49:14 End of Measurement (normal).	[Icon]
MBC_NN_B3_S7_PG_03.04_20250417_1152.ngb-sh4 Thermal Conductivity Test	17/04/2023 12:58:21 End of Measurement (normal).	[Icon]